

Will Rooftop Solar Really Add to Utility Costs?

By Suma Jothibasu and Surya Santoso
Posted 24 Jan 2017 | 21:00 GMT

Regulations in most states obligate utilities to derive some of their electricity generating capacity from renewable sources. Unsurprisingly, the most widely available options—wind and solar—dominate. The International Energy Agency (IEA) estimates that by 2050, solar photovoltaic (PV) power generation will contribute 16 percent of the world's electricity, and 20 percent of that capacity will come from residential installations.

By offering local generation, residential or rooftop PV reduces the need for transmission facilities to move power from large generating stations to distribution substations. But the effect on the distribution grid is less straightforward. The conventional distribution grid is designed for neither two-way power flow nor large generation capacity. So the prevailing thought is that the grid will need a costly upgrade to accommodate the high PV penetration. Our study within the [Full Cost of Electricity](http://energy.utexas.edu/the-full-cost-of-electricity-fce/) (<http://energy.utexas.edu/the-full-cost-of-electricity-fce/>) program aims to estimate the cost of maximizing residential PV capacity without any grid impacts. The bottom line? We found that even without hardware upgrades to the distribution circuits, such circuits can handle significant solar generation.

We looked at it three ways: Allowing the largest PV generation

1. without making operational changes to the circuit or upgrading the infrastructure;
2. with a few modest operational changes in the equipment already installed; and
3. with additional infrastructure upgrades such as smart inverters and energy storage.

(Note that accommodating the first two capacities does not require any integration costs, beyond some minimal cost associated with the operational changes in the existing devices.)

Depending on a distribution circuit's characteristics, the maximum PV capacities it can handle range from as low as 15.5 percent of the median value of the daytime peak load demand (2.6 megawatts in one particular circuit) to more than 100 percent (3.87 MW in another circuit). These results suggest that significant rooftop PV generation can be integrated in the grid with little or no additional cost to utilities and their customers and without causing any adverse grid impacts. In fact, our study shows that at such levels, impacts due to PV generation are either non-existent or can be addressed by appropriate circuit operational changes.

In one example, an operational change was able to boost photovoltaic capacity from 15 percent to 47 percent. The PV hosting capacity of the circuit in that same example can be boosted to 80 percent if as many as one-third of the photovoltaic installations include smart inverter technologies.

Although adding energy storage would also increase hosting capacity, we find that the cost of energy storage systems would be significant, and so it is unjustifiable if the sole purpose is to increase PV penetration.

For details of which circuit characteristics affect photovoltaic capacity, as well as other calculations, read the complete white paper "Integrating Photovoltaic Generation (http://energy.utexas.edu/files/2016/09/UTAustin_FCe_Int_PV_Generation_2016.pdf)" [PDF], part of the Full Cost of Electricity Study conducted by the [University of Texas Austin Energy Institute](http://energy.utexas.edu/) (<http://energy.utexas.edu/>). (*IEEE Spectrum* is blogging about the study and linking to the white papers as they are released.)

Suma Jothibasu is a graduate student and [Surya Santoso](http://aspire.ece.utexas.edu/bio.html) (<http://aspire.ece.utexas.edu/bio.html>) directs the Laboratory for Advanced Studies in Electric Power and Integration of Renewable Energy Systems, within the Department of Electrical Engineering, Cockrell School of Engineering at the University of Texas Austin.



Photo: Lester Lefkowitz




Image: UT Austin

The amount of a photovoltaic capacity that can be added to a distribution circuit without violating its operating constraints depends on the specific nature of the system. The minimum hosting capacity, shown as Circuit C, is 15 percent. The maximum hosting capacity with no changes to the distribution circuit, Circuit B, is 104 percent of median daytime peak load.